



- SERBATOIO REALIZZATO SU SPECIFICHE DEL CLIENTE
 - STORAGE TANK REALIZED ON CUSTOMER SPECIFICATIONS
 - BALLON REALISE' SUR SPECIFIQUE DU CLIENT

POS.	DESCRIPTION:	MATERIAL:	Q.TY:	CODE:	REVISIONS:
12					
11					
10	Internal thread 2"x50 mm	S235JR	1	91710681	
9	Lower coil WWM 200 da 3,0 mq Att.1"	S235JR	1	91510543	
8	C. Pipe 1 1/2 x 220 mm at 25°	S235JR	1	91630222	
7	Flange Ø180/Ø120	S235JR	1	91C20021	
6	Upper Semifinished	S235JR	1	F01151S3814	
5	Lower Semifinished	S235JR	1	I01151S3814	
4	Metal sheet 1561x1250x25/10	S235JR	1	912S3814 91120251	
3	Internal thread 1 1/2"x50 mm	S235JR	1	91710570	
2	Internal thread 3/4"x50 mm	S235JR	3	91710212	
1	Internal thread 1/2"x50 mm	S235JR	3	91710060	

TESTING PRESSURE IS ONE AND A HALF OF WORKING PRESSURE

EFFECTIVE CAPACITY (LT.):	PRIMARY CAPACITY (LT.):	PRIMARY WORKING PRESSURE (BAR):	SECONDARY CAPACITY (LT.):	SECONDARY WORKING PRESSURE (BAR):	WEIGHT (KG):
273	...	10	115

ALL RIGHTS RESERVED. THIS DRAWING IS NOT TO BE GIVEN TO THIRD PARTS WITHOUT OUR WRITTEN AUTHORIZATION

MATERIAL:	TREATMENT:	DESCRIPTION:
S235JR	SMALGLASS	PROSTOR SC 300
FIRST ANGLE PROJECTION:	DESIGNER:	DATE CREATED:
	D. MATTIOLI	29-08-17
DIMENSIONS IN MILLIMETERS	CHECKED:	Commercial Hot Water Solutions Ltd.
TOLERANCES NOT SHOWN:	CHECKED:	CODE:
EN 22768-1 - V	...	B01301S3814

Updated serpentine (D.Mattioli)
 Changed 1/2" connection in axis with flange to 2" on request of client (F. Perina)
 Changed connection of Mg Anode on request of client (F. Perina)
 Created drawing