



- SERBATOIO REALIZZATO SU SPECIFICHE DEL CLIENTE
 - STORAGE TANK REALIZED ON CUSTOMER SPECIFICATIONS
 - BALLON REALISE SUR SPECIFIQUE DU CLIENT

01

POS.	DESCRIPTION:	MATERIAL:	Q.TY:	CODE:	REVISIONS:
12					
11					
10					
9	Lower coil T60x30 5.0mq Att. 1 1/4	S235JR	1	91560058	
8	Flange Ø180/Ø120	S235JR	1	91C20021	
7	Upper Semifinished	S235JR	1	F014.01S3816	
6	Lower Semifinished	S235JR	1	I014.01S3816	
5	Metal sheet 2031x1230x25/10	S235JR	1	912S3816 91120121	
4	C. Pipe 2" x 220 mm at 25°	S235JR	1	91630228	
3	Internal thread 2"x50 mm	S235JR	2	91710681	
2	Internal thread 3/4"x50 mm	S235JR	3	91710212	
1	Internal thread 1/2"x50 mm	S235JR	3	91710060	

TESTING PRESSURE IS ONE AND A HALF OF WORKING PRESSURE

EFFECTIVE CAPACITY (LT.):	PRIMARY CAPACITY (LT.):	PRIMARY WORKING PRESSURE (BAR):	SECONDARY CAPACITY (LT.):	SECONDARY WORKING PRESSURE (BAR):	WEIGHT (KG):
475	...	10	155

ALL RIGHTS RESERVED. THIS DRAWING IS NOT TO BE GIVEN TO THIRD PARTS WITHOUT OUR WRITTEN AUTHORIZATION

MATERIAL:	TREATMENT:	DESCRIPTION:
S235JR	SMALGLASS	PROSTOR SC 500

FIRST ANGLE PROJECTION:	DESIGNER:	DATE CREATED:
	D. MATTIOLI	29-08-17
DIMENSIONS IN MILLIMETERS	CHECKED:	Commercial Hot Water Solutions Ltd.
TOLERANCES NOT SHOWN:	CHECKED:	CODE:
EN 22768-1 - V	...	B0150153816