



Final draft, agreed and signed 12.1.21

Andy Clifford

- SERBATOIO REALIZZATO SU SPECIFICHE DEL CLIENTE
- STORAGE TANK REALIZED ON CUSTOMER SPECIFICATIONS
- BALLON REALISE SUR SPECIFIQUE DU CLIENT

POS.	DESCRIPTION:	MATERIAL:	Q.TY:	CODE:	REVISIONS:
12					
11	Flap Ø35/45	S235JR	1	91920013	
10	Internal thread 2"x105 mm	S235JR	3	91710710	
9	Screw TE M6x10 mm	GALVANIZED	1	98120010	
8	Nut M6x30mm	S235JR	1	98610001	
7	Flange Ø290	S235JR	1	91C10016	
6	Upper Semifinished	DD12/S235JR	1	F08504S3860	
5	Lower Semifinished	DD12/S235JR	1	I085040030	
4	Metal sheet 2031x1230x25/10	DD12	1	912S3860 91120121	
3	Internal thread 1"1/4x105 mm	S235JR	1	91710500	
2	Internal thread 3/4"x105 mm	S235JR	3	91710240	
1	Internal thread 1/2"x105 mm	S235JR	3	91710130	

TESTING PRESSURE IS ONE AND A HALF OF WORKING PRESSURE

EFFECTIVE CAPACITY(LT.):	PRIMARY CAPACITY (LT.):	PRIMARY WORKING PRESSURE (BAR):	SECONDARY CAPACITY (LT.):	SECONDARY WORKING PRESSURE (BAR):	WEIGHT (KG):
490	...	10	125

ALL RIGHTS RESERVED. THIS DRAWING IS NOT TO BE GIVEN TO THIRD PARTS WITHOUT OUR WRITTEN AUTHORIZATION

MATERIAL:	TREATMENT:	DESCRIPTION:
S235JR / DD12	SMALGLASS	PROSTOR BV 500
FIRST ANGLE PROJECTION:	DESIGNER:	DATE CREATED:
	D. MATTIOLI	21-09-17
DIMENSIONS IN MILLIMETERS	CHECKED:	Commercial Hot Water Solutions Ltd.
TOLERANCES NOT SHOWN:	G. ZENARI	CODE:
EN 22768-1 - V	CHECKED:	B09504S3860

17-12-20 Added 2" on the side on request of client (F. Per...)
21-09-17 Created drawing