


Final draft, agreed and signed 12.1.21

*Andy Clifford*



- SERBATOIO REALIZZATO SU SPECIFICHE DEL CLIENTE  
- STORAGE TANK REALIZED ON CUSTOMER SPECIFICATIONS  
- BALLON REALISE SUR SPECIFIQUE DU CLIENT

01

POS.	DESCRIPTION:	MATERIAL:	Q.TY:	CODE:	REVISIONS:
12					
11	Flap Ø35/45	S235JR	1	91920013	
10	Internal thread 2"x105 mm	S235JR	3	91710710	
9	Screw TE M6x10 mm	GALVANIZED	1	98120010	
8	Nut M6x30mm	S235JR	1	98610001	
7	Flange Ø290	S235JR	1	91C10016	
6	Upper Semifinished	DD12/S235JR	1	F08504S3860	
5	Lower Semifinished	DD12/S235JR	1	I085040030	
4	Metal sheet 2031x1000x25/10	DD12	1	912S3859 91120090	
3	Internal thread 1 1/4"x105 mm	S235JR	1	91710500	
2	Internal thread 3/4"x105 mm	S235JR	3	91710240	
1	Internal thread 1/2"x105 mm	S235JR	3	91710130	08 05 04 03 02 01 00

TESTING PRESSURE IS ONE AND A HALF OF WORKING PRESSURE					
EFFECTIVE CAPACITY(LT.):	PRIMARY CAPACITY (LT.):	PRIMARY WORKING PRESSURE (BAR):	SECONDARY CAPACITY (LT.):	SECONDARY WORKING PRESSURE (BAR):	WEIGHT (KG):
398	...	10	...	...	...
ALL RIGHTS RESERVED. THIS DRAWING IS NOT TO BE GIVEN TO THIRD PARTS WITHOUT OUR WRITTEN AUTHORIZATION					
MATERIAL:	TREATMENT:	DESCRIPTION:			
S235JR / DD12	SMALGLASS	PROSTOR BV 400			
FIRST ANGLE PROJECTION:	DESIGNER:	Commercial Hot Water Solutions Ltd.		DATE CREATED:	
	D. MATTIOLI			22-09-17	
TOLERANCES NOT SHOWN:	CHECKED:	G. ZENARI		CODE:	
EN 22768-1 - V	...			B09404S3859	

17-12-20 Changed recatulation to 2" and added 2" on the side on request of client (F. Merello)  
22-09-17 Created drawing